

**Prebid Clarifications for UPS****NIT No. - BSEDC/3032/10 dated 07/07/2010**

<b>S.No</b>	<b>Bidders Query</b>	<b>Tender Ref. Page No.</b>	<b>Topic</b>	<b>BSEDC Clarification</b>
	<b>Queries received from Numeric Power Systems Ltd.</b>			
1	As per tender document warranty is three years on UPS and Battery, but as per all Battery manufacturer warranty is only one year on SMF battery. So battery warranty should be changed one year and UPS warranty should be 3 years.	Page No. 37 and General Terms	General Terms	The Warranty on UPS and Battery required is 3 Years.
2	As you know power condition and distribution is very poor in Bihar, we request yu to add Isolation transformer at the input of UPS which will arrest some of the Spikes.	Page No. 37 Technical Specs	General Query	It is left to the Bidders to Offer the same as an additional item, and BSEDC will consider based on the requirement.
3	As per tender page No. 5 the cost of tender document given Rs.- 10,000/- but as per Tender dociment page No. 15 the cost of tender document given 5,000/-, so pls let us know what will be the tender fee amount.	Page No. 5 and 15	Bid Cost	The Cost of the Bid Document is Rs. 5,000/-
4	EMD Validity for 15 months			6 Months